

57 fudsomst

MEMORANDUM

| | | | |
|---------|-------------------------------------------------------|----------------|-------------|
| TO | Building Department - Att: Mr. C. Seraphin | DEPT.-LOCATION | |
| FROM | Housing Div., Bureau of F & S | DEPT.-LOCATION | |
| SUBJECT | 57 Judson Street - Fire Dept. Housing Survey Referral | DATE | 2 / 12 / 57 |

MESSAGE:

Violations:

1. Amateur wiring throughout. *Electrical pardoned 2/14/57 C.F.S*
2. Old baker's oven attached to house.
3. Walls in weaken condition.

ORIGINATOR - DO NOT WRITE BELOW THIS LINE

SIGNED

John C. Pottery

REPLY:

DEPT.-LOCATION

SIGNED

DATE

/ /

SEND PARTS 1 AND 3 WITH CARBON INTACT - PART 3 WILL BE RETURNED WITH REPLY

INSPECTION REPORT

DEPT. OF LICENSES AND INSPECTIONS

CITY OF HARTFORD

57 Judson St.

H.S.

LOCATION

2 1/2 STORY FRAME.

PERMIT NO.

DATE ISSUED

REMARKS:

Inspection discloses, baker's oven in rear of building is in dilapidated condition. Demolish baker's oven. Foundation walls in need of repair. Rebuild and repair brick and stone foundation.

2-14-57. J.S.B.

owner:

Harry Bassell

Estelle Cherlin

Myrtle B Cohen

10 Mrs Daniel Cherlin
209 Campbell Ave

February 15, 1957

Mrs. Daniel Cherlin, Agent
209 Campfield Avenue
Hartford, Connecticut

Re: 57 Judson Street

Dear Mrs. Cherlin:

Upon receipt of complaint from the Housing Division, an inspection of the above property, recorded as owned by you, disclosed the following conditions in need of immediate attention:

The baker's oven in the rear of the building is in a dilapidated condition. Kindly demolish baker's oven. Also, foundation walls are in need of repair. Rebuild and repoint brick and stone foundation.

You are hereby notified to cause the above items to be properly corrected on or before February 25, 1957 and to secure the necessary permits required from this office.

Very truly yours,

John S. Barnecki,
Assistant Building Inspector

JSB
MB

Wanna Comp. J.S.B.

57 Judson Street

March 4, 1957

Mr. Harry Bassell et al
90 Harwich Street
Hartford, Connecticut

Re: 57 Judson Street

Dear Mr. Bassell:

Upon receipt of complaint from the Fire Department, an inspection of the above property, recorded as owned by you, disclosed the following conditions in need of immediate attention:

There are extension cords coming up from the cellar through the upper floors. Also, there is amateur wiring throughout the building.

You are hereby notified to cause the above items to be properly corrected on or before March 14, 1957, and to secure the necessary permits required from this office.

Very truly yours,

Joseph F. Piccolillo,
Assistant Electrical Inspector

JFP:oj

57 Judson Street

CITY OF HARTFORD CONNECTICUT
INTER-DEPARTMENTAL EXCHANGE OF INFORMATION

DATE Feb. 1, 1957

FROM FIRE PREVENTION BUREAU
HARTFORD FIRE DEPT. TO Building Dept. - Electrical Insp.

ADDRESS 57 Judson St.

STRUCTURE OR SITE 3 story frame

OWNER H Cherlin ADDRESS 209 Campfield Ave

REFERRED FOR Extension cords from cellar thru upper floors.

ACTION CONTEMPLATED BY ORIGINAL DEPARTMENT _____

6 _____

George F. Kennedy

FIRE MARSHAL

DISPOSITION _____

L. Stevens
Fire Prev.

57 Judson St.